

## Minutes of the Prebid Meeting

Date : 12.06.2024.

Time : 3.30 to 5.30 PM.

Venue : M-14 & Online

Work: Proposed Additional & Modifications Works to Existing MDC Block @ Survey No 47, Mahanthalingapura Village, Jigani Hobli Anekal Taluk, Bengaluru urban district.

Ref: NIT No.PM/NIIMB/MDC/2024-25/01

Attendance Sheet enclosed.

During the Prebid Meeting following queries were raised by the Vendors.

- I) Queries raised by M/s Effects Engineers Bengaluru.
- 1) The fabrication details for HSD Tank as per Item No III (1) is requested.  
During the meeting Architects clarified that the double skin HSD tank of 990 Litres to be made of MS tank of 5mm thickness each tank with halar coating. Shop drawing to be furnished by vendor for approval by Architects.
  - 2) Details specifications of 0.5 HP fuel Pump as per item No III( 2) is requested.  
Makes from Rotodel /Grundfos / Equivalent are approved by Architects.
  - 3) Wrt tender item part -I Item (1) The Aluminium Sections should be from M/s. SCHUECO TROP TEC/ REYNAERS/ KAWNEER are approved. The other makes specified in tender like Jindal, ECIE, Hindalco, Bhoroka is deleted.  
The work should confirm to technical specifications in pages 222 to 225.
  - 4) Make of Material for the item No VII (1) & VII (2)  
For the tender item no VII, (1) to (4) following brands are also approved by the Architects.  
Approved make : Basant Beston/shobha/Parijatha/Super Tile.

Note: The Minutes of Prebid Meeting will form part of the Agreement.

  
Project Manager, IIMB

